


INSTALLATION INSTRUCTIONS FOR L-904 ADJUSTABLE "L" CONNECTOR

NOTE: For use with L-650 Series Track system ONLY
Electrical Ratings: 120V, 60HZ, 20A

NOTE: Ground contact (Silver) must be on the same side as the Polarity Groove of the track. If Polarity Groove and Ground Contact does not line up remove 2-screws from cover, remove cover and adjust connector 180° as shown. Install cover and screws. (If used as a Power Feed DO NOT INSTALL COVER until wire connections are made as noted below.)

STEP 1: Insert ends of connector into ends of track (Ground Contact (Silver) must line up with Polarity Groove of track.) Secure to track by tightening lock screws at the tip of connector until snug. DO NOT OVER TIGHTEN. This may distort track.



NOTE: If used as a Power Feed Point

STEP 1: Remove plastic plug button from back plate pull supply wires through center connect power supply colored (Line) to brass screw marked "P" white (Neutral) to nickel plated screw marked "N". Ground to green screw when required.