



Orion[®] Multigas Detector Combustible Sensor (20F) Replacement Kit

Sensor Replacement

Proper installation (when used in conjunction with the replacement procedure provided in the instrument instruction manual), includes the following:

1. Verify that the instrument is turned OFF remove battery pack.
2. If your unit is a pumped version, remove the pump cover by removing the screw with a 1/16-inch hex key.
3. Remove the sensor cover screws and cover.
4. Gently lift out the sensor to be replaced; properly dispose of the sensor.
5. If replacement sensor is equipped with a shorting plate, clip or wire attached to its pins, remove plate, clip or wire before inserting the replacement sensor.
6. Carefully align new sensor contact pins with the sockets on the printed circuit board designated for the combustible sensor.
 - Sensor positions cannot be changed. Each sensor location is identified by a label in the bottom of each sensor well. When replacing a sensor, ensure that the gas type printed on the sensor label matches the sensor identification label in the instrument.
7. Fully seat the sensor, flat against the printed circuit board.
8. Press the new sensor into place.
9. Replace the sensor gasket and sensor cover.
10. Re-install the screws to hold down the sensor cover.
11. Properly reassemble the instrument according to the instrument instruction manual.

⚠ WARNING

Verification of calibration response is required; otherwise the instrument cannot perform as required and persons who rely on this product for their safety could sustain serious personal injury or death.

Typical Performance Specifications

RANGE	0 TO 100% LEL
RESOLUTION	1% LEL
REPRODUCIBILITY	3% LEL to 50% LEL reading
	5% LEL to full scale
RESPONSE TIME	90% of final reading in 30 seconds (normal temperature range)

Relative Responses to Combustible Gases

The following relative responses to selected combustible gases are typical of an Orion Multigas Detector calibrated using Pentane.

COMBUSTIBLE GAS	MULTIPLY %LEL READING BY	COMBUSTIBLE GAS	MULTIPLY %LEL READING BY
Acetone	1.1	Methanol	0.6
Acetylene	0.7	Methyl Isobutyl ketone	1.1
Acrylonitrile ¹	0.8	Methylcyclohexane	1.1
Benzene	1.1	Methyl Ethyl Ketone	1.1
Butane	1.0	Methyl Tertiary Butyl Ether	1.0
1,3 Butadiene	0.9	Mineral Spirits	1.1
n-Butanol	1.8	iso-Octane	1.1
Carbon Disulfide ¹	2.2	n-Pentane	1.0
Cyclohexane	1.1	Propane	0.8
2,2 Dimethylbutane	1.2	Propylene	0.8
2,3 Dimethylpentane	1.2	Styrene ²	1.9
Ethane	0.7	Tetrahydrofuran	0.9
Ethyl Acetate	1.2	Toluene	1.1
Ethyl Alcohol	0.8	Vinyl Acetate	0.9
Ethylene	0.7	VM&P Naptha	1.6
Formaldehyde ²	0.5	o-Xylene	1.2
Gasoline (unleaded)	1.3	Response Notes: 1. The compounds may reduce the sensitivity of the combustible gas sensor by poisoning or inhibiting the catalytic action. 2. These compounds may reduce the sensitivity of the combustible gas sensor by polymerizing on the catalytic surface. 3. For an instrument calibrated on Pentane, multiply the displayed %LEL value by the conversion factor above to get the true %LEL. 4. These conversion factors should be used only if the combustible gas is known. 5. These conversion factors are typical for a Orion Multigas Detector. Individual units may vary by $\pm 25\%$ from these values.	
Heptane	1.1		
Hydrogen	0.6		
n-Hexane	1.3		
Isobutane	0.9		
Isobutyl Acetate	1.5		
Isopropyl Alcohol	1.1		
Methane	0.5		